

## **SECTION 224000 - PLUMBING FIXTURES**

### **PART 1 - GENERAL**

- 1.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following conventional plumbing fixtures and related components:

1. Commercial Sinks.
2. Faucets for Commercial Sinks.
3. Electric water coolers.
4. Fixture supports.
5. Fixture Service Stops.
6. Fixture Drains, Traps, tail pieces, and strainers

- B. Related Sections include the following:

1. Division 22 Section "Domestic Water Piping Specialties" for backflow preventers, floor drains, and specialty fixtures not included in this Section.
2. Division 22 Section "Plumbing Insulation" for insulation requirements.

#### **1.3 DEFINITIONS**

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. ADA Accessible Fixture: Plumbing fixture that can be approached, entered, and used by people with disabilities.
- C. Cast Polymer: Cast-filled-polymer-plastic material. This material includes cultured-marble and solid-surface materials.
- D. Cultured Marble: Cast-filled-polymer-plastic material with surface coating.
- E. Fitting: Device that controls the flow of water into or out of the plumbing fixture. Fittings specified in this Section include supplies and stops, faucets and spouts, shower heads and tub spouts, drains and tailpieces, and traps, waste and indirect waste pipes. Piping and general-duty valves are included where indicated.
- F. FRP: Fiberglass-reinforced plastic.
- G. PMMA: Polymethyl methacrylate (acrylic) plastic.
- H. PVC: Polyvinyl chloride plastic.
- I. Solid Surface: Nonporous, homogeneous, cast-polymer-plastic material with heat-, impact-, scratch-, and stain-resistance qualities.
- J. LF: Lead Free

## 1.4 SUBMITTALS

- A. Product Data: For each type of plumbing fixture indicated. Include selected fixture and trim, fittings, accessories, appliances, appurtenances, equipment, and supports. Indicate materials and finishes, dimensions, construction details, and flow-control rates.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Operation and Maintenance Data: For all plumbing fixtures to include in emergency, operation, and maintenance manuals.
- D. Warranty: Special warranty specified in this Section.

## 1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain plumbing fixtures, faucets, and other components of each category through one source from a single manufacturer.
  - 1. Exception: If fixtures, faucets, or other components are not available from a single manufacturer, obtain similar products from other manufacturers specified for that category.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Regulatory Requirements: Comply with requirements in ICC A117.1, "Accessible and Usable Buildings and Facilities; Public Law 90-480, "Architectural Barriers Act"; and Public Law 101-336, "Americans with Disabilities Act"; for plumbing fixtures for people with disabilities.
- D. Regulatory Requirements: Comply with requirements in Public Law 102-486, "Energy Policy Act," about water flow and consumption rates for plumbing fixtures.
- E. NSF Standard: Comply with NSF 61, "Drinking Water System Components--Health Effects," for fixture materials that will be in contact with potable water. Comply with Reduction of Lead in Drinking Water Act "Lead Free Law".
- F. Select combinations of fixtures and trim, faucets, fittings, and other components that are compatible.
- G. All vitreous china fixture trapways shall be fully glazed internally.
- H. Comply with the following applicable standards and other requirements specified for lavatory and sink faucets:
  - 1. Faucets: ASME A112.18.1.
  - 2. Hose-Connection Vacuum Breakers: ASSE 1011.
  - 3. Hose-Coupling Threads: ASME B1.20.7.
  - 4. Integral, Atmospheric Vacuum Breakers: ASSE 1001.
  - 5. NSF Potable-Water Materials: NSF 61.
  - 6. Pipe Threads: ASME B1.20.1.
  - 7. Supply Fittings: ASME A112.18.1.
  - 8. Brass Waste Fittings: ASME A112.18.2.
  - 9. Trap and Supply Insulation: ANSI A117.1.

10. Federal "Reduction of Lead in Drinking Water Act" – 2011.
- I. Comply with the following applicable standards and other requirements specified for shower faucets:
  1. Backflow Protection Devices for Hand-Held Showers: ASME A112.18.3M.
  2. Combination, Pressure-Equalizing and Thermostatic-Control Antiscald Faucets: ASSE 1016.
  3. Faucets: ASME A112.18.1.
  4. Hand-Held Showers: ASSE 1014.
  5. High-Temperature-Limit Controls for Thermal-Shock-Preventing Devices: ASTM F 445.
  6. Hose-Coupling Threads: ASME B1.20.7.
  7. Manual-Control Antiscald Faucets: ASTM F 444.
  8. Pipe Threads: ASME B1.20.1.
  9. Pressure-Equalizing-Control Antiscald Faucets: ASTM F 444 and ASSE 1016.
  10. Thermostatic-Control Antiscald Faucets: ASTM F 444 and ASSE 1016.
- J. Comply with the following applicable standards and other requirements specified for miscellaneous fittings:
  1. Atmospheric Vacuum Breakers: ASSE 1001.
  2. Brass and Copper Supplies: ASME A112.18.1.
  3. Brass Waste Fittings: ASME A112.18.2.
- K. Comply with the following applicable standards and other requirements specified for miscellaneous components:
  1. Pipe Threads: ASME B1.20.1.

## **PART 2 - PRODUCTS**

### 2.1 MANUFACTURERS

- A. COMMERCIAL SINKS – STAINLESS STEEL
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Elkay Manufacturing Co.
    - b. Just Manufacturing Company.
    - c. Amtekco, a Wasserstrom Company.
- B. SINK FAUCETS
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Delta Faucet Company.
    - b. Moen.
    - c. Chicago Faucets.
- C. ELECTRIC WATER COOLERS, BOTTLE FILLING STATIONS
  1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Elkay USA
    - b. Halsey Taylor
    - c. Haws
- D. FIXTURE SUPPLIES, STOPS

1. Manufacturers: Subject to compliance with requirements, provide lead-free products by one of the following:
  - a. McGuire Manufacturing Co., Inc.
  - b. Fluidyne Ansonia.
  - c. BrassCraft.

### E. FIXTURE DRAINS, TRAPS, TAILPIECES AND STRAINERS

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Dearborn Brass
  - b. McGuire Manufacturing Co., Inc.
  - c. Brasscraft.

### F. FIXTURE SUPPORTS

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Jay R. Smith Mfg. Co.
  - b. Tyler Pipe; Wade Div.
  - c. Zurn.

## 2.2 FIXTURES

### A. **SK-1** Sink –Single Bowl – ADA Compliant

1. Fixture: Elkay Mfg. Co. # ELUHAD211555.
2. Faucet: Chicago Faucet # 895-317GN8AE29VPCP.
3. Strainer: Elkay Mfg. Co. # LK-99.
4. Trap: Dearborn # 710DF-1, 1-1/2", 17 gauge, cast-brass "P" trap with CO plug and escutcheon.
5. Supplies: McGuire # BV2165, loose key, riser length as required.

### B. **EW-1** Electric Water Cooler

1. Halsey Taylor # HAC8FSBLR-WF-Q ADA, lead-free, satin finish.
2. Trap: Dearborn # 710DF-1, 1-1/2", 17 gauge, cast-brass.
3. Valve: 1/2" lead-free in-line valve, threaded ends, Brasscraft # OR82-C, lead-free.
4. Note: Refer to Architectural drawings for mounting height.

## 2.3 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before plumbing fixture installation.
- B. Examine cabinets, counters, floors, and walls for suitable conditions where fixtures will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

## 2.4 INSTALLATION

- A. Assemble plumbing fixtures, trim, fittings, and other components according to manufacturers'

written instructions.

- B. Install off-floor supports, affixed to building substrate, for wall-mounting fixtures.
  - 1. Use carrier supports with waste fitting and seal for back-outlet fixtures.
  - 2. Use carrier supports without waste fitting for fixtures with tubular waste piping.
- C. Install back-outlet, wall-mounting fixtures onto waste fitting seals and attach to supports.
- D. Install wall-mounting fixtures with tubular waste piping attached to supports.
- E. Install counter-mounting fixtures in and attached to casework.
- F. Install fixtures level and plumb according to roughing-in drawings.
- G. Install water-supply piping with stop on each supply to each fixture to be connected to water distribution piping. Attach supplies to supports or substrate within pipe spaces behind fixtures. Install stops in locations where they can be easily reached for operation.
  - 1. Exception: Use lead-free ball valves if supply stops are not specified with fixture. Valves are specified in Division 22 Section "General-Duty Valves for Plumbing Piping."
- H. Install trap and tubular waste piping on drain outlet of each fixture to be directly connected to sanitary drainage system.
- I. Install traps on fixture outlets.
  - 1. Exception: Omit trap on fixtures with integral traps.
  - 2. Exception: Omit trap on indirect wastes, unless otherwise indicated.
- J. Install escutcheons at piping wall ceiling penetrations in exposed, finished locations and within cabinets and millwork. Use deep-pattern escutcheons if required to conceal protruding fittings. Escutcheons are specified in Division 22 Section "Common Work Results for Plumbing."
- K. Seal joints between fixtures and walls, floors, and countertops using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Sealants are specified in Division 07 Section "Joint Sealants."

## 2.5 CONNECTIONS

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- C. Connect owner furnished fixtures and equipment per manufacturer's requirements and as noted on the plans.
- D. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."
- E. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

## 2.6 FIELD QUALITY CONTROL

- A. Verify that installed plumbing fixtures are categories and types specified for locations where installed.
- B. Check that plumbing equipment and fixtures are complete with trim, faucets, fittings, and other specified components.
- C. Inspect installed plumbing fixtures for damage. Replace damaged fixtures and components.
- D. Test installed fixtures after water systems are pressurized for proper operation. Replace malfunctioning fixtures and components, then retest. Repeat procedure until units operate properly.

## 2.7 ADJUSTING

- A. Operate and adjust faucets and controls. Replace damaged and malfunctioning fixtures, fittings, and controls.
- B. Adjust water pressure at faucets and flushometer valves to produce proper flow and stream.
- C. Clean all aerators and flow screens.
- D. Replace washers and seals of leaking and dripping faucets and supply stops.

## 2.8 CLEANING

- A. Clean fixtures, faucets, drains and other fittings with manufacturers' recommended cleaning methods and materials. Do the following:
  - 1. Remove faucet spouts and strainers, remove sediment and debris, and reinstall strainers and spouts.
  - 2. Remove sediment and debris from drains and drain bodies.
  - 3. Clean all roof, floor drain and floor sink grates.
- B. After completing installation of exposed, factory-finished fixtures, faucets, and fittings, inspect exposed finishes and repair damaged finishes.

## 2.9 PROTECTION

- A. Provide protective covering during construction for all installed fixtures and fittings.
- B. Do not allow use of plumbing fixtures for temporary facilities unless approved in writing by Owner.

### **PART 3 - EXECUTION** (Not Applicable)

END OF SECTION 224000