

BULLETIN ADDENDUM 03

Date Issued: February 24, 2025

Project Name: ECC Respiratory Care – Columbia Campus

Project Number/Phase: 24-3465.01/BN

Prepared By: David Wolff, Sophia Stone

Distribution: Ryan Wilson, Amy Miller (Navigate)
Jon Bauer, Robyn Walter, Nancy Mitchell, Karen Hayes (ECC)
Mason Ryan, Jason Heisler, Tim Filiatreau (IMEG)
Alexis Rains, Chrissy Rogers (Arcturis)

Please note the following changes and/or clarifications to the original Construction Documents dated 01/30/25:

Heading Number 1 – Project Manual

Item	Section	Action	Description
1-1	003132	ADD	Added Columbia Campus Pre-Bid Conference Sheet
1-2	003132	ADD	Added Columbia Campus Pre-Bid Conference Attendance List
1-3	003132	ADD	Added Boone County Prevailing Wage information
1-4	092900	DELETE	Deleted all references to Level 5 finish
1-5	260500	REMOVE	Removed 1.3.D.2-3
1-6	260500	REMOVE	Removed 1.9.1 260513 Wire and Cable
1-7	260500	REMOVE	Removed 1.9.1 260520 Grounding and Bonding
1-8	260500	REMOVE	Removed 1.9.1 260533 Conduit and Boxes
1-9	260500	REMOVE	Removed 1.9.1 260553 Electrical Identification
1-10	260513	REMOVE	Removed 1.1 D-G
1-11	260513	REMOVE	Removed 1.4 Submittals
1-12	260513	REMOVE	Removed 2.1.I
1-13	260513	REMOVE	Removed 2.4
1-14	260513	REMOVE	Removed 2.5
1-15	260513	REMOVE	Removed 2.6
1-16	260513	REMOVE	Removed 3.1.A.2
1-17	260513	ADD	Added 3.1.A.2-4
1-18	260513	REMOVE	Removed 3.1.D
1-19	260513	REMOVE	Removed 3.8 AC, MC Cable Installation
1-20	260553	REMOVE	Removed 1.4 Submittals
1-21	260553	REMOVE	Removed 3.7 D.1
1-22	260933	REMOVE	Removed 1.2.A.1 and 1.2.A.3
1-23	260933	REMOVE	Removed 1.9.D
1-24	260933	REMOVE	Removed 1.10: Mockup and Samples of Submitted Devices.
1-25	260933	REMOVE	Removed 2.2.A.1
1-26	260933	ADD	Added 2.2.A.1
1-27	260933	REMOVE	Removed 3.1 Pre-Construction meeting
1-28	260933	REMOVE	Removed 3.4.D Training
1-29	260933	REMOVE	Removed 3.5 System Commissioning
1-30	262726	REMOVE	Removed 1.1 B, D-K
1-31	262726	REMOVE	Removed 1.5 C
1-32	265119	REMOVE	Removed 1.4.D
1-33	270500	REMOVE	Removed Section 1.2, D, 1. f.

1-34	270500	REMOVE	Removed Section 1.4, E, 4.
1-35	270500	REMOVE	Removed Section 1.7, A. 1 -27 05 03
1-36	270500	REMOVE	Removed Section 1.8 and 1.9
1-37	270500	REMOVE	Removed Section 3.9, C. 8.
1-38	270526	REMOVE	Removed specification section in its entirety.
1-39	270800	REMOVE	Removed specification section in its entirety.
1-40	271100	REMOVE	Removed specification section in its entirety.
1-41	271500	REMOVE	Removed Section 2.1, A. 8.
1-42	271500	REMOVE	Removed Section 2.1, B.
1-43	271500	REMOVE	Removed Section 2.2
1-44	271500	REMOVE	Removed Section 2.3, B
1-45	271710	REMOVE	Removed Section 2.1, A, b.
1-46	271720	REMOVE	Removed Section 1.2 B. and C.
1-47	271720	REVISE	Revised Section 2.1 TIA/EIA 568A to 568B.

Heading Number 2 – Drawings

Item	Sheet	Action	Description
2-1	G-000	REVISE	Revised Notes to Bidders #3 regarding Allowances
2-2	A-001	CLARIFY	Clarified existing floor to ceiling height
2-3	A-801	REVISE	Revised headwall assembly to be provided by Contractor
2-4	P201	ADD	Added medical gas outlet callout for each headwall.
2-5	P600	REVISE	Revised headwall description.
2-6	P600	ADD	Added medical gas outlet group description to material list.
2-7	P60	ADD	Added outlet types and description to material list.
2-8	P600	ADD	Added plumbing insulation schedule.
2-9	E000	ADD	Added lens to fixture type F2.
2-10	E000	ADD	Added lumens to fixture type F2
2-11	E000	ADD	Removed switch leg column on Luminaire Schedule.
2-12	E000	ADD	Added sequence to LD1 on the Lighting Sequence of Operations.
2-13	E000	ADD	Added sequence to LD2 on the Lighting Sequence of Operations.
2-14	E000	REVISE	Revised the luminaire shading key.
2-15	E000	REMOVE	Removed reference to fire in electrical renovation, phasing, and installation notes.
2-16	E101	REMOVE	Removed receptacles not in scope.
2-17	E101	REVISE	Sheet Note to reference E000 not E001.
2-18	E101	REVISE	Revised keynote 5 to specify location of termination.
2-19	E101	REVISE	Revised to reference "New Work" over "Renovation".
2-20	E201	REMOVE	Revised keynote 5 to coordinate projector receptacle mounting.
2-21	E201	REVISE	Revised Sheet Note to reference E000 not E001.
2-22	E201	REVISE	Revised circuit tags to not include panel name.
2-23	E201	REVISE	Revised storage quad to circuit #19
2-24	E201	REVISE	Revised projector circuit to match panel

2-25	E600	REVISE	schedule.
2-26	E600	REVISE	Revised existing heating A/C load.
2-27	E600	REVISE	Revised circuit #3 breaker from 25A to 20A.
2-28	E600	REVISE	Revised the voltage drop for circuit #12.
			Revised name of label for three-pole circuit on circuit #18,20, and 22.
2-29	E600	REVISE	Revised breaker type for circuit #16 to new load on existing breaker.
2-30	E600	ADD	Added designation "Demo" to Panel P-2 to show distinction between demo and new work.
2-31	T000	REMOVE	Removed technology outside plant notes and other non- applicable details.
2-32	T000	REVISE	Revised technology symbol list information outlet (ceiling) symbol from C# to RI
2-33	T201	ADD	Added existing equipment to demo plan
2-34	T201	ADD	Added demo plan sheet notes 1, 2 and keynote 1.
2-35	T201	ADD	Added wall mounted rack to Level 1 plan.
2-36	T201	REVISE	Revised Level 1 plan - keynote 2
2-37	T400	REVISE	Revised Detail 1, to show J-Hook detail in leu of cable tray.
2-38	T400	ADD	Added Detail 3, typical connectivity riser diagram.
2-39	T600	REMOVE	Removed CJ6X8TP from equipment list.

Heading Number 3 – Notifications

3-1 N/A

END OF ADDENDUM 03.