

ADDENDUM NO. 6

Date: 2025-08-12
From: Jim Shearer, Lawrence Group
Architect's Project No. 2024110
Project: East Central College – Rolla Campus
Owner: East Central College
1964 Prairie Dell Rd.
Union, MO 63084

Owners Representative: Navigate Building Solutions
8419 Manchester Rd.
St. Louis, MO 63144

This Addendum is issued before execution of Contract to inform the Bidders of revisions to the Bid Documents and shall be included in the contract.

All requirements contained in the Bidding Documents shall apply to the Addendum. The work called for in this Addendum shall be the same as set forth in the applicable portions of the Bidding Documents unless otherwise specified in this Addendum. All incidental work necessitated by this Addendum as required to properly complete the work shall be included in the Bids even though not specifically stated in this Addendum.

Specification Addenda

1 Contract Documents - A-101 – 2017 Standard Form of Agreement Between Owner and Contractor

1.1 Revise Paragraph 8.7.4 to read:

Permits: Contractor shall obtain and pay for all required permits, licenses, and approvals as applicable to the Contractor's Work.

Drawing Addenda

2 MV201C LEVEL 01 PLAN VENTILATION – AREA C

2.1 Welding booths and Fume Collection Arms are to be furnished and installed by Contractor, as indicated on the Architectural Drawings.

Revise note on sheet MV201C outside Welding space regarding Welding Booths and Fume Collection Hoods to read:

WELDING BOOTH AND FUME COLLECTION ARM TO BE CONTRACTOR PROVIDED AND CONTRACTOR INSTALLED. MECHANICAL CONTRACTOR TO PROVIDE CONNECTION TO FUME COLLECTION ARM ACCORDING TO MANUFACTURER'S RECOMMENDATIONS. SEE EQUIPMENT SCHEDULE ON ARCHITECTURAL DRAWINGS FOR PRODUCT INFORMATION.